

ADDENDUM NO. 1

TO: All Vendors
FROM: Jason McGarry, Procurement/Contracts Administrator
SUBJECT: CARTA2020-04 Post Mounted Solar Lighting
DATE: May 11, 2020

This Addendum No. 1 modifies the Request for Proposal (RFP) only in the manner and to the extent as stated herein.

QUESTIONS AND ANSWERS

- 1) **What initial and annual quantities are estimated to be ordered?**
 - a. Undetermined at this time
- 2) **What is the dimension and standard for CARTA posts for the solar lights to be mounted to?**
 - a. 2" square post
- 3) **Will you accept lithium-ion battery instead of lead acid?**
 - a. Yes
- 4) **Must the reserve capacity sustain the FULL 5.0 foot candle illumination for up to 48 hours without additional charging input or is any reduced illumination to extend runtime acceptable?**
 - a. Reduced illumination is acceptable
- 5) **Should the required lighting level (5.0 foot candles of illuminations measured eight feet (8') from the light source) be measured at ground level?**
 - a. Yes
- 6) **What is CARTA's preferred luminaire mounting height?**
 - a. 8'
- 7) **Does CARTA have a preference of color temperature? Is 4000K acceptable?**
 - a. No
 - b. Yes

Offeror shall acknowledge receipt of Addendum No. 1 in the space provided below and return with their proposal. Failure to do so will subject the proposal to rejection.

Authorized Signature

Company Name

Date